CE
0333

Certificat
Certificate

Certificate of constancy of performance for smoke alarm device

In compliance with the Regulation 305/2011/UE of the European Parliament and of the Council of 9 March 2011 (Construction Products Regulation or CPR)

Delivered by:

Certification body:	**AFNOR Certification**
Identification number:	**0333**
Address:	**11, rue Francis de Pressensé** **FR-93571 La Plaine Saint-Denis Cedex**

Issued to:

Manufacturer	**LIFE SAFETY DISTRIBUTION GmbH**
Address:	**Javastrasse 2 8604 HEGNAU SUISSE**
Manufacturing site:	**HONEYWELL LIFE SAFETY ROMANIA SRL LUGOJ ROUMANIE**

Description of the product: see Annex

AFNOR Certification attests that the provisions concerning the assessment and verification of constancy of performance and the performances described in annex ZA of the standard EN 14604 : 2005 + AC : 2008 under system 1 and that smoke alarm device fulfills the provisions described in annex ZA of the standard EN 14604 : 2005 + AC : 2008.

Certificate number: **0333-CPR-292135**

Conditions and certificate validity period: this certificate was first issued on 1/18/2016.
Unless suspended or withdrawn, this certificate remains valid as long as the conditions laid down in the harmonized technical specifications or the manufacturing conditions in the factory or the factory production control itself are not significantly modified.

This certificate cancels and replaces any previous certificate

Date of issue of the certificate: 1/17/2021

Certificate expiry date : 1/17/2026

cofrac
CERTIFICATION DE PRODUITS ET SERVICES
ACCRÉDITATION N° 5-0030 PORTÉE DISPONIBLE SUR WWW.COFRAC.FR

Julien NIZRI
Managing Director of AFNOR Certification

CE
0333

Annexe
Appendix

Annex to the certificate issued on 1/17/2021: 0333-CPR-292135

Manufacturer **LIFE SAFETY DISTRIBUTION GmbH**
Address: **Javastrasse 2 8604 HEGNAU SUISSE**

Manufacturing site: **HONEYWELL LIFE SAFETY ROMANIA SRL LUGOJ ROUMANIE**

Product description:

Commercial reference	XS100
Trade mark	HONEYWELL
Type of mouting	Wall or Ceiling
Main power supply	Internal power source
Battery name	Ultra 123 (Duracell) Industrial CR123A (Panasonic)
Battery duration	10 years
Connection of external ancillary devices	No
Individual alarm indicator	Yes
Interconnectable device	Yes
Suitable for installation in recreational vehicles	Yes
Alarm silence facility	Yes
File number	292.0635 292.0651

This annex cannot be submitted or reproduced without the document to which it is attached.